

KEMA TYPE TEST CERTIFICATE OF SHORT-CIRCUIT PERFORMANCE

was issued to

Astor Transformator A.S.

Ankara, Turkey

for the test object:

a three-phase oil-immersed

power transformer

Type: Power transformer with OLTC

Rating: 32 MVA / 40 MVA – 66 kV \pm 8 x 1,25% / 11,86 kV – Dyn11 – 50 Hz

manufactured by

Astor Transformator A.S.

Ankara, Turkey

The test object has successfully passed the required type tests of


IEC 60076-5

The test results are recorded in Certificate No.

2251-19

This Certificate was issued on 20 September 2019

KEMA B.V.



Shankar Subramany

Director, High-Power Laboratory



KEMA

Laboratories

© DNV GL

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that DNV GL has certified or approved any object other than the specimen tested.